

NPDES Permit No. IL0069736
Notice No. SMT:15090301.smt

Public Notice Beginning Date: **October 7, 2015**

Public Notice Ending Date: **November 6, 2015**

National Pollutant Discharge Elimination System (NPDES)
Permit Program

Draft Reissued NPDES Permit to Discharge into Waters of the State

Public Notice/Fact Sheet Issued By:

Illinois Environmental Protection Agency
Bureau of Water,
Division of Water Pollution Control
Permit Section
1021 North Grand Avenue East
Post Office Box 19276
Springfield, Illinois 62794-9276
217/782-0610

Name and Address of Discharger:

City of Decatur
#1 Gary K. Anderson Plaza
Decatur, Illinois 62523

Name and Address of Facility:

City of Decatur PWS
DeWitt County Emergency Well Field
Section 36, T19N, R2E, 3rd PM
Decatur, Illinois 62523
(DeWitt County)

The Illinois Environmental Protection Agency (IEPA) has made a tentative determination to issue a NPDES permit to discharge into the waters of the state and has prepared a draft permit and associated fact sheet for the above named discharger. The Public Notice period will begin and end on the dates indicated in the heading of this Public Notice/Fact Sheet. The last day comments will be received will be on the Public Notice period ending date unless a commentor demonstrating the need for additional time requests an extension to this comment period and the request is granted by the IEPA. Interested persons are invited to submit written comments on the draft permit to the IEPA at the above address. Commentors shall provide his or her name and address and the nature of the issues proposed to be raised and the evidence proposed to be presented with regards to those issues. Commentors may include a request for public hearing. Persons submitting comments and/or requests for public hearing shall also send a copy of such comments or requests to the permit applicant. The NPDES permit and notice number(s) must appear on each comment page.

The application, engineer's review notes including load limit calculations, Public Notice/Fact Sheet, draft permit, comments received, and other documents are available for inspection and may be copied at the IEPA between 9:30 a.m. and 3:30 p.m. Monday through Friday when scheduled by the interested person.

If written comments or requests indicate a significant degree of public interest in the draft permit, the permitting authority may, at its discretion, hold a public hearing. Public notice will be given 45 days before any public hearing. Response to comments will be provided when the final permit is issued. For further information, please call Shu-Mei Tsai at 217/782-0610.

The applicant is engaged in the operation of a public water supply (SIC 4941). City of Decatur discharges an average of 25.92 MGD of groundwater from Outfall 001 to recharge Lake Decatur.

Application is made for the existing discharge which is located in DeWitt County, Illinois. The following information identifies the discharge point, receiving stream and stream classifications:

Outfall	Receiving Stream	Latitude		Longitude		Stream Classification	Biological Stream Characterization
001	Friends Creek tributary to Sangamon River to Lake Decatur	40° 03' 58"	North	88° 48' 20"	West	General Use	Not Rated

To assist you further in identifying the location of the discharge please see the attached map.

The waterbody segment receiving the discharge from outfall(s) 001 unnamed tributary to Friends Creek with zero 7Q10 flow is not on the draft 2012 Illinois Integrated Water Quality Report and Section 303(d) List as it has not been assessed. The receiving water has not been given an integrity rating or been listed as biologically significant in the 2008 Illinois Department of Natural Resources publication *Integrating Multiple Taxa in a Biological Stream Rating System*.

The discharge(s) from the facility shall be monitored and limited at all times as follows:

Outfall: 001 Groundwater (DAF = 25.92 MGD)

PARAMETER	LOAD LIMITS lbs/day		REGULATION	CONCENTRATION		REGULATION
	30 DAY AVERAGE	DAILY MAXIMUM		30 DAY AVERAGE	DAILY MAXIMUM	
Flow (MGD)						35 IAC 309.146
Flow (MG)						35 IAC 309.146
pH						35 IAC 302.204
Total Suspended Solids				15	30	35 IAC 304.124
Iron (Total)				2.0	4.0	35 IAC 304.124

The following explain the conditions of the proposed permit:

Special Conditions include the descriptions of flow reporting, monitoring location, pH, discharge monitoring reports, and re-opener.



NPDES Permit No.IL0069736

Illinois Environmental Protection Agency

Division of Water Pollution Control

1021 North Grand Avenue East

Post Office Box 19276

Springfield, Illinois 62794-9276

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM

Reissued (NPDES) Permit

Expiration Date:

Issue Date:

Effective Date:

Name and Address of Permittee:

Facility Name and Address:

City of Decatur
#1 Gary K. Anderson Plaza
Decatur, Illinois 62523

City of Decatur PWS
DeWitt County Emergency Well Field
Section 36, T19N, R2E, 3rd PM
Decatur, Illinois 62523
(DeWitt County)

Discharge Number and Name:

001 Groundwater

Receiving Waters:

Friends Creek tributary to Sangamon River to Lake
Decatur

In compliance with the provisions of the Illinois Environmental Protection Act, Title 35 of Ill. Adm. Code, Subtitle C and/or Subtitle D, Chapter 1, and the Clean Water Act (CWA), the above-named permittee is hereby authorized to discharge at the above location to the above-named receiving stream in accordance with the standard conditions and attachments herein.

Permittee is not authorized to discharge after the above expiration date. In order to receive authorization to discharge beyond the expiration date, the permittee shall submit the proper application as required by the Illinois Environmental Protection Agency (IEPA) not later than 180 days prior to the expiration date.

Alan Keller, P.E.
Manager, Permit Section
Division of Water Pollution Control

SAK:SMT:15090301.smt

NPDES Permit No.IL0069736

Effluent Limitations and Monitoring

1. From the effective date of this permit until the expiration date, the effluent of the following discharge(s) shall be monitored and limited at all times as follows:

Outfall: 001 Groundwater (DAF = 25.92 MGD)

PARAMETER	LOAD LIMITS lbs/day DAF (DMF)		CONCENTRATION LIMITS mg/l		SAMPLE FREQUENCY	SAMPLE TYPE
	30 DAY AVERAGE	DAILY MAXIMUM	30 DAY AVERAGE	DAILY MAXIMUM		
Flow (MGD)	See Special Condition 1				Continuous	Estimate
Flow (MG)	See Special Condition 1				Continuous	Total
pH	See Special Condition 2				1/Week When Discharging	Grab
Total Suspended Solids			15	30	1/Week When Discharging	Grab
Iron (Total)			2.0	4.0	1/Week When Discharging	Grab

NPDES Permit No. IL0066613

Special Conditions

SPECIAL CONDITION 1. Flow (in MGD) shall be reported as a monthly average and a daily maximum. The total volume discharged per month shall also be reported (in MG), and shall be calculated using the capacity of each pump, and the duration of pumping at each well.

SPECIAL CONDITION 2. The pH shall be in the range 6.5 to 9.0. The monthly minimum and monthly maximum values shall be reported on the DMR form.

SPECIAL CONDITION 3. Samples taken in compliance with the effluent monitoring requirements shall be taken at a point representative of the discharge, but prior to entry into the receiving stream.

SPECIAL CONDITION 4. The Permittee shall record monitoring results on Discharge Monitoring Report (DMR) Forms using one such form for each outfall each month.

In the event that an outfall does not discharge during a monthly reporting period, the DMR Form shall be submitted with no discharge indicated.

The Permittee may choose to submit NetDMR instead of mailing paper DMRs to the IEPA. More information, including registration information for the NetDMR program, can be obtained on the IEPA website, <http://www.epa.state.il.us/water/net-dmr/index.html>

The completed Discharge Monitoring Report forms shall be submitted to IEPA no later than the 28th day of the following month, unless otherwise specified by the permitting authority.

Permittees not using NetDMRs shall mail Discharge Monitoring Reports with an original signature to the IEPA at the following address:

Illinois Environmental Protection Agency
Division of Water Pollution Control
1021 North Grand Avenue East
Post Office Box 19276
Springfield, Illinois 62794-9276

Attention: Compliance Assurance Section, Mail Code # 19

SPECIAL CONDITION 5. If an applicable effluent standard or limitation is promulgated under Sections 301(b)(2)(C) and (D), 304(b)(2), and 307(a)(2) of the Clean Water Act and that effluent standard or limitation is more stringent than any effluent limitation in the permit or controls a pollutant not limited in the NPDES Permit, the Agency shall revise or modify the permit in accordance with the more stringent standard or prohibition and shall so notify the permittee.

